



Kiwa UK Regulation 4 (KUKreg4) Approval (ATS3)

Certificate number 2008720
Date issued 17th August 2020
Date expired 16th August 2025 Original/Amendment *Original*

Description: Mini city and Mini eco range of heat interface units (HIU) with twin stainless steel copper brazed plate heat exchangers providing hot water or hot water and a cold water outlet. The hot water is generated via a plate heat exchanger.
The cold inlet supply elbow of the F3 & F5 models only incorporates an in line single check valve assembly, (suitable for backflow protection against Fluid Category 2). The F3 and F5 models also have a wholesome cold water outlet supply.
The primary circuit incorporates an expansion vessel and a pressure relief valve (set at 2.5 bar). Mini eco models have connections at the top and bottom of the unit whereas the Mini City the only have bottom connections.
Maximum working pressures and operating temperatures:
Primary (district heating): 16.0 bar and 120°C.
Domestic hot water (DHW): 2.5 bar and 90°C.
Secondary (space heating): 5.5 bar and 90°C.

UK Approval

Issued by Kiwa Watertec

Product Designation: Cetetherm Mini Eco F3, F4, F5 & F7 &
Cetetherm Mini City F3, F4, F5 & F7.

This is to certify that the above range of products manufactured/supplied by

Company name: Cetetherm AB

Has been tested and found to comply with the requirements of the Water Supply (Water Fittings) Regulations 1999 for England and Wales, the Water Byelaws 2014, Scotland and the Water Regulations, Northern Ireland.

This certificate must be read in conjunction with the acceptance letter for this product.

This approval is intended for compliance with the above Regulations and must not be considered equivalent to the product certification provided by Kiwa N.V.

To comply with the Regulations and Byelaws all products require the correct installation. Details of the installation requirements (IRNs) can be obtained from the acceptance letter supplied with this certificate.

Applicable IRNs for this certificate: R001, R360

David Jay, Business Unit Manager – Authorised Signatory

Certificate issued to:

Cetetherm AB
Fridhemsvägen 15
S-372 38 Ronneby
Sweden

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
F +44 (0)495 304496
uk.water@kiwa.com
www.kiwa.co.uk



CERTIFICATE

390170301