



Certificate number: 2402761 (1)

Issued 28/02/2024

Expires 28/02/2029

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Cetetherm AB.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:

Cetetherm AB
Fridhemsvagen 15
SE-372 38
Ronneby
Sweden



KUKreg4

Product Certificate

Appendix to Certificate number: 2402761

The following products belong to this certificate

<p>PRODUCT DESCRIPTION Range of Heat Interface Units with stainless steel and copper heat exchangers and fitted with a safety relief valve set a 6 bar. The inlet incorporates a stainless strainer and a single check valve. The primary side is fitted with an expansion vessel and safety relief valve. The units are fitted with a filling loop assembly, consisting of a stainless steel braided EPDM lined flexible hose, a lever operated brass spherical valve and a DZR brass double check valve assembly that incorporates a lever operated spherical valve.ATS3 – Without Production Surveillance.</p>
<p>MODEL(S) 739490 Pi-H1-T1-GE1-E-H-0_6W-3-E-E-1x130-UK 739491 Pi-H1-T1-GE1-E-H-0_6W-3-E-E-1x130-UK-230</p>
<p>SIZE: See model.</p>
<p>SCOPE: Manufacturer recommended maximum working pressure: Primary circuit 16 bar, Heating circuit 2.5 bar, DHW circuit 5.5 bar & maximum operating temperature: Primary circuit 120°C, Heating circuit 90°C, DHW circuit 90°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C.</p>
<p>MARKING Manufacturers name, model, manufacturing number, date and technical information.</p>
<p>MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.</p>
<p>BACKFLOW PROTECTION NOTES No supply pipe or secondary circuit shall be permanently connected to a closed circuit for filling a heating system unless it incorporates an appropriate backflow prevention device.</p>
<p>ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.</p> <p>Sealed primary circuits and /or secondary hot water systems shall incorporate a means for accommodating the thermal expansion of water to prevent any discharge from the circuit and/or system except in an emergency situation.</p>

Extra Notes